

*Midwestern Higher Education Compact
Energy Advisory Committee*

ELECTRICAL COMPONENTS SOLUTION

REQUEST FOR PROPOSAL

Addendum

Feb. 24, 2010

Section I. 2. Specifications (page 9)

A third paragraph has been added to the section I. 2. Specifications which reads in its entirety:

“Eligible Participants may require additional special minor modifications to accommodate standards adopted by the Eligible Participant. Should these additional special minor modifications require an adjustment to the cost associated with the specifications, the adjusted cost shall be presented to Eligible Participant and Eligible Participant may elect to incorporate those modifications at the stated prices.”

Section I. 2. Specifications. Electrical Lamps. Category 1: Individual Lamps. F (page 10)

The GE Watt-Miser® Mod-U-line® T12 30 Watt specification has been deleted in its entirety and replaced with:

“GE Watt-Miser® Mod-U-line® T8 30 Watt”

Section I. 2. Specifications. Variable Frequency Drives. 1.1 Purpose (page 28)

The paragraph has been changed to include Yaskawa and Allen Bradley in the list of approved manufacturers with similar equipment.

Section I. 2. Specifications. Variable Frequency Drives. 1.3.7 (page 29)

This section has been changed and now reads in its entirety as:

“The Drive shall provide an RS-485 Modbus, Siemens FLN, Johnson N2, Lonworks, BACnet and/or other serial communications port(s) as required by standards for Eligible Participant purchasing the drives.”

Section I. 2. Specifications. Variable Frequency Drives. 4.0.1 (page 29)

This section has been changed and now reads in its entirety as:

“The Drive shall be designed to operate at either 200-260Vac, 380-500Vac or 525-600Vac Three-Phase input voltage as required by eligible participant purchasing the Drives.”

Section I. 2. Specifications. Variable Frequency Drives. 4.0.7 (page 30)

This section has been deleted and completely removed from the document.

Section I. 2. Specifications. Variable Frequency Drives. 5.0.1 (page 30)

The first sentence of this section has been changed in its entirety to now read as:

“The Drive model line shall be capable of Horsepower ratings from 1 to 60 HP at 208/230Vac, from 1 to 500 HP at 460Vac, and Output Frequencies from 0 to 1000 Hz (recognizing drives over 60 HP will require close coordination of features with Eligible Participant purchasing the drives).”

Section I. 2. Specifications. Variable Frequency Drives. 5.0.7 (page 30)

The following second sentence has been added to the end of the section:

“If 150% overload current rating for one (1) minute and/or higher ratings are required by standards for Eligible Participant purchasing the drives then prospective providers shall provide pricing for those components.”

Section I. 2. Specifications. Variable Frequency Drives. 7.0.23 (page 33)

This section has been deleted and completely removed from the document.

Section I. 2. Specifications. Variable Frequency Drives. 7.0.25 (page 33)

This section has been changed and now reads in its entirety as:

“Drive shall have built-in communications to support Modbus RTU, Siemens FLN, Johnson N2, Lonworks, BACnet and/or other as required by Eligible Participant as standard.”

Section I. 2. Specifications. Variable Frequency Drives. 9.0.4 (page 38)

This section has been changed and now reads in its entirety as:

“The Drive shall be provided with a minimum of two (2) analog output signals as follows:”

Section I. 2. Specifications. Variable Frequency Drives. 9.0.5.1 (page 38)

This section has been changed and now reads in its entirety as:

“Protocol: Modbus RTU, Siemens FLN, Johnson N2, LonWorks, BACnet and/or other as required by standards for Eligible Participant purchasing the Drives.”

Section I. 2. Specifications. Variable Frequency Drives. 11.0.2 (page 38)

Section 11.0.2 has been changed and now reads in its entirety as:

“The Drive Vendor shall provide a Warranty for material and workmanship for a period of twenty-four (24) months. If required by the drive manufacturer to maintain warranty, on-site factory start-up assistance shall be provided as part of the base price.”

Section I. 2. Specifications. Variable Frequency Drives. 11.0.3 (pages 38-39)

Section 11.0.3 has been changed to 11.0.4 and a new section 11.0.3 is added after section 11.0.2 which reads in its entirety as:

“If an extended warranty and services are requested by Eligible Participant at the time of purchase, prospective provider shall make available such warranty and services at additional cost.”